

IMPORTANT INFORMATION

CONSUMER CONFIDANCE REPORT FOR THE CALANDER YEAR 2019

Annual Drinking Water Quality Report FOR THE VILLAGE OF HOMER, IL State ID# IL0190300

The source of drinking water used by THE Village of HOMER is ground water.

Annual Water Quality Report for the period of January 1 to December 31, 2019

This report is intended to provide you with important information about your drinking water and the efforts made by the water system to provide safe drinking water. For more information regarding this report contact: Sharon Jeffers (Village Clerk) at 217/896/2521 or Edward Shirley (Operator in Charge) at 217/260/6479.

Este informe contiene información muy importante sobre el agua que usted bebe. Tradúzcalo ó hable con alguien que lo entienda bien.

Source of Drinking Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pickup substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include: - Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife. - Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming. - Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses. - Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems. - Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPAs Safe Drinking Water Hotline at (800) 426-4791.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health. Some people may be more vulnerable to contaminants in drinking water than the general population.

Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Source Water Information

The Village of Homer presently draws water from WELL 2 (47661) GW 453 FT W AND 440 FT S OF PLANT, WELL 3 (47662) GW 0.25 MILES WEST OF PLANT, and WELL 4 (00731) GW 100 FEET WEST OF PLANT as well as WELL 5 (01265) GW (EAST WELL) and WELL 6 (01266) GW (WEST WELL) 1.5 MI WSW OF OGDEN.

Source Water Assessment

We want our valued customers to be informed about their water quality. If you would like to learn more, please feel welcome to attend any of our regularly scheduled meetings on the second Monday of each month at 7:00pm. The source water assessment for our supply has been completed by the Illinois EPA. If you would like a copy of this information, please stop by City Hall or call our water operator at 217/260/6479. To view a summary version of the completed Source Water Assessments, including: Importance of Source Water; Susceptibility to Contamination Determination; and

documentation/recommendation of Source Water Protection Efforts, you may access the Illinois EPA website at <http://www.epa.state.il.us/cgi-bin/wp/swap-fact-sheets.pl>. To determine Homer's susceptibility to groundwater contamination, a Well Site Survey, published in 1991 by the Illinois EPA, and a source inventory by the IRWA were reviewed. Based on the information contained in this document, four potential sources of groundwater contamination are present that could pose a hazard to groundwater pumped by the Homer community water supply wells. These include a below ground fuel storage, a former petroleum facility, and two auto repairs. The Illinois EPA has determined that Homer Wells #2, #3, #4, #5, and #6 are not susceptible to IOC, VOC, or SOC contamination. This determination is based on a number of criteria including: monitoring conducted at the wells; monitoring conducted at the entry point to the distribution system; and the available hydrogeologic data for the wells.

LEAD AND COPPER

Definitions:

Action Level Goal (ALG): The level of a contaminant in drinking water below which there is no known or expected risk to health. ALGs allow for a margin of safety

Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow

Lead and Copper	Date Sampled	MCLG	Action Level (AL)	90th Percentile	# of Sites Over AL	Units	Violation	Likely Source of Contamination
Copper	9/29/2017	1.3	1.3	1.1	1	ppb	N	Erosion from natural deposits: Leaching from wood preservatives: Corrosion from household plumbing systems
Lead	9/29/2017	0	1.5	1.1	0	ppb	N	Erosion from natural deposits: Corrosion from household plumbing systems

Water Quality Test Results

Maximum Contaminant Level Goal or MCLG: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Contaminant Level or MCL: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum residual disinfectant level goal or MRDLG: The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Maximum residual disinfectant level or MRDL: The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Definitions: The following tables contain scientific terms and measures, some of which may require explanation.

Level 1 Assessment: is a study of the water system to identify potential problems and determine (if possible) why Total Coliform bacteria have been found in our system.

Level 2 Assessment: is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. Coli MCL Violation has occurred and/or why Total Coliform bacteria have been found in our system on multiple occasions.

ppb: micrograms per liter or parts per billion - or one ounce in 7,350,000 gallons of water.

na: not applicable.

Avg: Regulatory compliance with some MCLs are based on running annual average of monthly samples.

ppm: milligrams per liter or parts per million - or one ounce in 7,350 gallons of water.

Regulated Contaminants

Disinfectants and Disinfectant ByProducts	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Chlorine	2019	2.1	1.5 – 2.1	MRDLG = 4	MRDL = 4	ppm	N	Water additive used to control Microbes
Haloacetic Acids (HAAs)	2019	12.18	11.3 – 12.18	No Goal for the Total	60	ppb	N	By-product of drinking water disinfection
Total Trihalomethanes (TTHMs)	2019	4.84	4.19 – 4.84	No Goal for the Total	80	ppb	N	By-product of drinking water disinfection

INORGANIC CONTAMINANTS	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Arsenic	6/21/2017	1.2	1.2 – 1.2	0	10	ppb	N	Erosion of natural deposits: Runoff from orchards: Runoff from Glass and Electronics production wastes
Barium	6/21/2017	0.17	0.17 - 0.17	2	2	ppm	N	Discharge of drilling waste: Discharge from metal refineries: Erosion of natural deposits
Fluoride	6/21/2017	0.619	0.619 - 0.619	4	4.0	ppm	N	Erosion of natural deposits: Water addition which promotes strong teeth: Discharge from fertilizer and aluminum factories
Iron	6/21/2017	0.09	0.09 - 0.09		1.0	ppm	N	This contaminant is not currently regulated by the USEPA. However, the state regulates it. Erosion of natural deposits
Manganese	6/21/2017	41	41 - 41	150	150	ppb	N	This contaminant is not currently regulated by the USEPA. However, the state regulates it. Erosion of natural deposits
Nitrate (measured as Nitrogen)	2098	0.14	0.14 – 0.14	10	10	ppm	N	Runoff from fertilizer use: Leaching from septic tanks, sewage: Erosion of natural deposits.
Nitrite (measured as Nitrogen)	9/27/2018	0.17	0.17 - 0.17	1	1	ppm	N	Runoff from fertilizer use: Leaching from septic tanks, sewage: Erosion of natural deposits.
Sodium	6/21/2017	42	42 - 42			ppm	N	Erosion of naturally occurring deposits: Used in water softener regeneration.
RADIOACTIVE CONTAMINANTS	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Combined Radium 226/228	2/6/2012	1.77	1.77 - 1.77	0	5	pCi/L	N	Erosion of Natural Deposits
Gross Alpha excluding radon and uranium	2/6/2012	0.12	0.12 - 0.12	0	15	pCi/L	N	Erosion of Natural Deposits